ESSENTIAL CHEMICAL

Scale Destroyer Tube Boiler Cleaning Procedure:

1. Power down the boiler.
2. Perform a blowdowns 10-15 seconds while maintaining pressure.
3. Drain and flush the boiler.
4. Secure the steam valve.
5. Introduce Essential Chemical ***Scale Destroyer*** and refill with water.
6. Circulate the mixture through the drain or low point, returning it from the pressure relief valve or high point into a vented container for 4-6 hours, depending on volume.
7. Reopen the steam valve.
8. Drain, flush, refill, and restart the boiler.
9. In cases where scale buildup is significant, additional treatment may be necessary.